

Radon Inspection Report

Test Location:	Test For:	Inspected By:
SAMPLE	,	Craig Pierce
Livingston, MT 59047		430 S. 6th, YOUR ADDRESS2
		Livingston, MT 59047
		(406)224-3562
	Inspection Type: Pre-Mitigation	
Building Type: Residential Single Family		

Test Device Details:	Test Site Condition:
Serial Number: 237179001	Condition: Overcast
Model Number: 1028XP	Wind: South West 0-5mph
Last Calibration: 12/29/2018	Structure Type:
Next Calibration: 12/29/2019	Year Built: 1910
Cal-Factors: 3.11	Sq Ft: 2210
Motion Error: Yes	

Test Summary:

<u>CRM Location:</u>	<u>Start:</u>	<u>Stop:</u>	<u>Interval:</u>	<u>Duration:</u>	Overall Avg: EPA	Average:
basement	01/14/2019 04:41	01/16/2019 04:41	1 hr	48 hr	5.7 pCi/l	5.7 pCi/l

Test Details:

	PM	PM		
	<u>Measurement</u>	<u>Min</u>	<u>Max</u>	<u>Average</u>
	<u>Units</u>			
Radon Concentration:	(pCi/l)	2.9	9.3	5.7

Test Result: Fail


Comments:



Lic/Cert Signature

Inspection Report Date:
01/17/2019

Radon Inspection Chart



Test Result: Fail

Test Location: Livingston, MT 59047

Inspection Report Date: 01/17/2019

Test Checklist

- The location of the detector was selected so the detector was not to be disturbed during testing.
- The monitor was not placed in an area of high humidity such as: Kitchen, laundry room, cellar, spa room, garage, crawl space or sump area.
- The detector was not located near drafts caused by HVAC vents, windows and doors.
- Whole house fans were turned off during the testing.
- The detector was not placed near areas of excessive heat, such as a fireplace or in direct sunlight.
- Portable window fans were removed or sealed in place prior to testing.
- The detector was placed within the breathing zone of at least 20 inches to 6 feet above the floor and at least 1 foot below the ceiling if suspended.
- Window air conditioners were operable in recirculation mode only.
- The detector was not placed within 1 foot of outside walls of the home or within 3 feet of any windows or doors to the exterior of the home.
- Ceiling fans, portable dehumidifiers, portable humidifiers, portable air filters, and all window air conditioners are not operated within 20 feet of the detector.

Test Result: Fail

Test Location: Livingston, MT 59047

Inspection Report Date:
01/17/2019



Absaroka Inspections LLC
 430 S. 6th YOUR ADDRESS2
 Livingston, MT 59047
 (406)224-3562

Test Data Table

Date/Time	Radon(nCi/l)	Temp(F)	Pres(inHa)	Humiditv(%)	Flaas
01/14/19 05:41 PM	3.9	-	-	-	-
01/14/19 06:41 PM	6.8	-	-	-	-
01/14/19 07:41 PM	6.4	-	-	-	-
01/14/19 08:41 PM	5.1	-	-	-	-
01/14/19 09:41 PM	5.5	-	-	-	-
01/14/19 10:41 PM	2.9	-	-	-	-
01/14/19 11:41 PM	3.9	-	-	-	-
01/15/19 12:41 AM	4.8	-	-	-	-
01/15/19 01:41 AM	3.2	-	-	-	-
01/15/19 02:41 AM	6.1	-	-	-	-
01/15/19 03:41 AM	4.2	-	-	-	-
01/15/19 04:41 AM	4.8	-	-	-	-
01/15/19 05:41 AM	5.8	-	-	-	-
01/15/19 06:41 AM	4.2	-	-	-	-
01/15/19 07:41 AM	5.8	-	-	-	-
01/15/19 08:41 AM	4.8	-	-	-	-
01/15/19 09:41 AM	3.9	-	-	-	-
01/15/19 10:41 AM	4.8	-	-	-	-
01/15/19 11:41 AM	6.4	-	-	-	-
01/15/19 12:41 PM	6.4	-	-	-	-
01/15/19 01:41 PM	4.5	-	-	-	-
01/15/19 02:41 PM	4.2	-	-	-	-
01/15/19 03:41 PM	4.8	-	-	-	-
01/15/19 04:41 PM	3.9	-	-	-	-
01/15/19 05:41 PM	7.4	-	-	-	-
01/15/19 06:41 PM	5.5	-	-	-	-
01/15/19 07:41 PM	6.8	-	-	-	-
01/15/19 08:41 PM	5.8	-	-	-	M
01/15/19 09:41 PM	6.4	-	-	-	-
01/15/19 10:41 PM	9.3	-	-	-	-
01/15/19 11:41 PM	6.4	-	-	-	-
01/16/19 12:41 AM	7.7	-	-	-	-
01/16/19 01:41 AM	8.7	-	-	-	-
01/16/19 02:41 AM	6.1	-	-	-	-
01/16/19 03:41 AM	7.1	-	-	-	-
01/16/19 04:41 AM	7.1	-	-	-	-
01/16/19 05:41 AM	8.4	-	-	-	-
01/16/19 06:41 AM	7.7	-	-	-	-
01/16/19 07:41 AM	6.8	-	-	-	-
01/16/19 08:41 AM	8.4	-	-	-	-
01/16/19 09:41 AM	7.7	-	-	-	-
01/16/19 10:41 AM	5.1	-	-	-	-
01/16/19 11:41 AM	7.4	-	-	-	-
01/16/19 12:41 PM	5.1	-	-	-	-
01/16/19 01:41 PM	3.5	-	-	-	-
01/16/19 02:41 PM	5.1	-	-	-	-
01/16/19 03:41 PM	4.2	-	-	-	-
01/16/19 04:41 PM	3.5	-	-	-	-

Test Result: Fail

Test Location: Livingston, MT 59047

Inspection Report Date: 01/17/2019

Radon Test Information

Radon Risk Information

Radon causes lung cancer by means of the decay of its daughter products after breathing in air contaminated with higher levels of Radon. The World Health Organization (WHO) estimates that 15% of lung cancers worldwide are caused by exposure to elevated indoor levels of Radon. Overall, radon is the second leading cause of lung cancer responsible for about 21,000 lung cancer deaths every year in the US alone. Radon gas is the number one cause of lung cancer among non-smokers. The U.S. Environmental Protection Agency (EPA), the U.S. Surgeon General, and the Center for Disease Control and Prevention (CDC) strongly recommend that ALL homebuyers have an indoor radon test performed prior to purchase or taking occupancy and recommend having the radon levels professionally mitigated if elevated radon concentrations are found.

Understanding Radon Test Results

Recommended Action Levels vary by country and typically range from 3 pCi/l (100 Bq/m³) to 8 pCi/l (300 Bq/m³). Recommendations below are based on test results by a Continuous Radon Monitor (CRM) Test of at least 24h duration and are based on recommendations by the EPA.

Measured Average Radon Level:

- Above 4 pCi/l (150 Bq/m³): Mitigation strongly recommended
- Between 2-4 pCi/l (75-150 Bq/m³): Consider mitigation or periodic retest as indoor Radon levels vary by season and weather conditions
- Below 2 pCi/l (75 Bq/m³): Consider bi-annual retest or whenever significant changes to the home structure or mechanical systems occurred

Test Result: Fail

Test Location: Livingston, MT 59047

Inspection Report Date:
01/17/2019
